

Test Verification of Conformity

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address : Shanghai Minmetals Development Ltd.
Minmetals Bldg. 757 Guangfu RD., Shanghai 200070, China

Manufacturer Name & Address : Shanghai Minmetals Development Ltd.
Minmetals Bldg. 757 Guangfu RD., Shanghai 200070, China

Product(s) Tested : Earth Clamp

Ratings and principal characteristics : For dry, non-corrosive conditions, or for corrosive or humid conditions, used for metal copper tube (including water, gas, heating and other service pipes), see annex for details.

Model(s) : EC14, EC14/2, EC14/3, EC15, EC15/2, EC15/3
EC16, EC16/2, EC16/3

Brand name : N/A

Relevant Standard(s) / Specification(s) / Directive(s) : BS 951:2009

Verification Issuing Office Name & Address : Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China

Verification Number : SH10100540-V1

Report Number(s) : SH10100540-001

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Leo Shi
Manager
November 19, 2010

Annex to Test Verification of Conformity

This is an Annex to Test Verification of Conformity with SH10100540-V1. The issuing office is Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China

Set 1: EC14, EC14/2, EC14/3

For dry, non-corrosive conditions, with screw type clamping unit, with clamping ability for 1X2,5-10mm² earthing conductor, with permanent warning tag in red color for distinction, all three type with similar construction, only different soft stainless steel band length and different range of metal tube diameter which for attached, see below for detail

EC14: for metal tube with diameter range from 12-32mm, soft stainless steel band with length of 135mm

EC14/2: for metal tube with diameter range from 32-50mm, soft stainless steel band with length of 195mm

EC14/3: for metal tube with diameter range from 50-75mm, soft stainless steel band with length of 290mm

Set 2: EC15, EC15/2, EC15/3

For corrosive or humid conditions, with screw type clamping unit, with clamping ability for 1X2,5-10mm² earthing conductor, with permanent warning tag in blue color for distinction, all three type with similar construction, only different soft stainless steel band length and different range of metal tube diameter which for attached, see below for detail

EC15: for metal tube with diameter range from 12-32mm, soft stainless steel band with length of 135mm

EC15/2: for metal tube with diameter range from 32-50mm, soft stainless steel band with length of 195mm

EC15/3: for metal tube with diameter range from 50-75mm, soft stainless steel band with length of 290mm

Annex to Test Verification of Conformity

This is an Annex to Test Verification of Conformity with SH10100540-V1. The issuing office is Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China

Set 3: EC16, EC16/2, EC16/3

For corrosive or humid conditions, with saddle clamping unit with clamping ability for 1X2,5-16mm² or 2X2,5-16mm² earthing conductor, with permanent warning tag in green color for distinction, all three type with similar construction, only different soft stainless steel band length and different range of metal tube diameter which for attached, see below for detail

EC16: for metal tube with diameter range from 12-32mm, soft stainless steel band with length of 135mm

EC16/2: for metal tube with diameter range from 32-50mm, soft stainless steel band with length of 195mm

EC16/3: for metal tube with diameter range from 50-75mm, soft stainless steel band with length of 290mm

NOTE: This annex is part of the Test Verification of Conformity and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Leo Shi
Manager
November 19, 2010