



## Fix4Fire

# Range Information

Product Code	Size mm	Head Type	Drill Diameter mm Hard Substrates	Drill Diameter mm Softer Substrates	Minimum Screw Embedment mm	Unit Oty
211-100-010	6x32	Pan	5.5	5	19	100
211-100-020	6x32	Oval	5.5	5	19	100

# **Applications**

- All steel screw fixing for direct fastening into many common building substrates
- Suitable for light to medium duty anchoring
- Will fix into wood and plasterboard without pre-drilling
- Can be directly screwed into sandstone, concrete, brick and stone with a pre-drilled pilot hole of 5.5mm. In softer substrates, 5mm may be more appropriate
- Designed to assist with compliance to BS 7671 amendment 3 and the Wiring Regulations 18th Edition
- Ideal for fixing fire resistant clips, consumer units, back boxes, conduit, cable trunking, smoke alarms etc.
- Remove the need to use plastic wall plugs which typically melt at circa 160°C

### **Specification**

- Made from heat treated C1018 1022 steel, 9.8 grade, with a Phillips recess, available with two head types
- Melting point of the material is circa 1500°C
- Tested to 975°C for a full 2 hours and retains its physical integrity
- Silver Ruspert® coated to 1000 hour salt spray specification for high corrosion resistance
- Resistant to fire, corrosion, solvents and chemicals

### **Olympic Fixing Products Ltd**

Units 1-3 Venture Court, Metcalf Drive Altham, Accrington Lancashire BB5 5WH

Tel: +44 (0)1282 778923 (5 lines) Fax: +44 (0)1282 779119

Sales Enquiries: accrington@olympicfixings.co.uk
General Enquiries: accrington@olympicfixings.co.uk
New Account Requests: tc@olympicfixings.co.uk

### **Olympic Fixings Ireland Ltd**

Unit 3, Greenway Industrial Estate Conlig, Co. Down BT23 7SU

Tel: +44 (0)2891 453724 (4 lines) Fax: +44 (0)2891 465893

Sales Enquiries: bangor@olympicfixingsireland.com

### www.olympicfixings.com

Registered Office: Units 1-3 Venture Court, Metcalf Drive, Altham, Accrington, Lancashire BB5 5WH